

Swans Nest Metropolitan District

April 2026

Prepared by Gabby Begeman and Jared Herzing

Analytical Results:

- 1) Total Coliform test from Hydrant 007 came back absent.
- 2) Monthly operations report completed and sent to the state without violations. The monthly operations report details all data collected from the treatment facility as logged every 15 minutes. We report this data to the state every month.
- 3) Entry Point Water Manganese (Treatment required if greater than 0.050 mg/l)
 - a) Average from weekly samples = 0.011 mg/l
 - b) Low 0.006 mg/l
 - c) High 0.015 mg/l

Water Production:

- 1) Total Production: 267,019 gallons
- 2) Average gallons per day: 8,900

Other Items:

- 1) Begin sampling from distribution system for manganese.