

Swans Nest Metropolitan District

March 2026

Prepared by Gabby Begeman and Jared Herzing

Analytical Results:

- 1) Total Coliform test from 7 Pelican Circle came back absent.
- 2) Raw Water Manganese (Treatment required if greater than 0.050 mg/l)
 - a) Average from weekly samples = 0.011 mg/l
 - b) Low 0.003 mg/l
 - c) High 0.018 mg/l

Water Production:

- 1) Total Production: 332,566 gallons
- 2) Average gallons per day 10,727

Other Items:

- 1) New bacti sample site added, Hydrant 007.
- 2) Mission System setup to report to ORC Water Professionals
- 3) Generator tested and verified to start automatically on power shutdown