



Water Quality Control Professionals LLC

December 19, 2025

Subject: Swan's Nest 4th Quarter Water Update

Analytical Results:

- 1) Total Coliform
 - a) October – Absent
 - b) November – Absent
 - c) December – Absent
- 2) Raw Water E. Coli
 - a) October – Absent
 - b) November – Absent
 - c) December – Absent
- 3) Raw Water Manganese (Treatment required if greater than 0.050 mg/l)
 - a) Average from weekly samples = 0.016 mg/l
 - b) Low 0.009 mg/l
 - c) High 0.040 mg/l

Water Production:

- 1) October 1st to December 18th Total 770,815 gallons
- 2) October 1st to December 18th Average gallons per day 9,757

Other Items:

- 1) Storage tank was inspected and cleaned by Inland Potable Divers on 9/30/2025.
- 2) Annual maintenance and flushing of hydrants were completed 10/14/2025



Water Quality Control Professionals LLC

Sincerely,

John M. Volk
Water Quality Control Professionals LLC
13863 W LaSalle Pl
Lakewood, CO 80228
970-389-4491
jvolk@wqcpllc.com

