

Swans Nest Metropolitan District

May 2026

Prepared by Gabby Begeman and Jared Herzing

Analytical Results:

- 1) Total Coliform test from Hydrant 001 came back absent.
- 2) Monthly operations report completed and sent to the state without violations. The monthly operations report details all data collected from the treatment facility as logged every 15 minutes. We report this data to the state every month.
- 3) State of Colorado organic sampling was completed and all results are non-detect. These results will be available to residents on the annual drinking water quality report next year.
- 4) Entry Point Water Manganese (Treatment required if greater than 0.050 mg/l)
 - a) Average from weekly samples = 0.010 mg/l
 - b) Low 0.005 mg/l
 - c) High 0.018 mg/l

Water Production:

- 1) Total Production: 445,598 gallons
- 2) Average gallons per day: 14,374 gallons

Other Items:

- 1) New bacti sample site added, Hydrant 001.
- 2) Additional filters ordered.
- 3) JVA Engineers made contact regarding the corrosion control treatment.